

VISIBLE & ULTRA VIOLET LIGHT TRANSMITTANCE
ASTM E 972 / ASTM E 1084
TEST REPORT

Bristolite®  Daylighting Systems

SERIES/MODEL: *Coollite*

TYPE: Skylight

Report Number: 94781.02-301-41

Test Date: 11/06/09

Report Date: 11/13/09

401 E. Goetz Avenue
Santa Ana, CA 92707
Phone: 800.854.8618
Phone: 714.540.8950
Fax: 714.540.5415
sales@bristolite.com
www.bristolite.com

VISIBLE & ULTRA VIOLET LIGHT TRANSMITTANCE VISIBLE & ULTRA VIOLET LIGHT REFLECTANCE



Report Number: 94781.02-301-41

Test Date: 11/06/09

Report Date: 11/13/09

Test Sample Identification:

Series/Model: Coollite

Type: Skylight

Overall Size: 47-1/2" x 47-1/2"

Test Procedure: Visible and Ultraviolet Light Transmittance and Reflectance testing was conducted in accordance with the following:

ASTM E 972, Standard Test Method for Solar Photometric Transmittance of Sheet Materials Using Sunlight.

ASTM E 1084, Standard Test Method for Solar Transmittance (Terrestrial) of Sheet Materials Using Sunlight.

Test Results Summary:

Ultraviolet Light Transmittance Clear flat structured sheet 0.08

* These values do not include the effects of edge or frame members

401 E. Goetz Avenue
Santa Ana, CA 92707
Phone: 800.854.8618
Phone: 714.540.8950
Fax: 714.540.5415
sales@bristolite.com
www.bristolite.com