

Certificate of Compliance

Certificate Number 20111110 – R14504
Report Reference R14504 – 1992 March 12
Issue Date 2011 November 10

Page 1 of 1



Issued to: **BRISTOL FIBERLITE INDUSTRIES, DBA BRISTOLITE SKYLIGHTS**
401 GOETZ AVE
SANTA ANA, CA 92707 USA

This is to certify that representative samples of **Roof Vents, Automatically Operated**


Automatically operated heat and smoke roof vents designated Model SVAM, SVAF, SVAA, SVSM, SVSF and SVSA. These units are constructed in widths of 4 to 5 ft and in lengths of 4 to 8 ft.

Have been investigated by Underwriters Laboratories in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: **ANSI/UL 793, "Automatically Operated Roof Vents for Smoke and Heat" and ULC/ORD-C793 -1973, "Guide for the Investigation of Automatically Operated Smoke and Heat Roof Vents."**

Additional Information: See UL On-line Certification Directory at WWW.UL.COM for additional information.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney
Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus>